

From: **Vetting** <vetting@safe-ships.sg>
Date: Thu, Nov 28, 2024 at 5:43 PM
Subject: Re: Fw: VESSEL CLEARANCE FOR MT JAVA SEA
To: Siti Aisah <siti.aisah@pseraya.com.sg>
Cc: SystemOps <systemops@pseraya.com.sg>, Othman <othman@pseraya.com.sg>

Dear Aisah,

Java Sea is cleared for fuel oil ops.

Vessel is suitable for Jetty 1 & 2.

There will be tidal restrictions for her berthing/unberthing at Jetty 1 & 2 if her draft exceeds 11.4m and 11.1m respectively.

Her Summer displacement of 127,352MT exceeded Jetty 1 & 2 acceptance criteria of 127,000MT.

Vessel should be reminded that her displacement should not exceed 127,000MT at all times.

Vessel's ballast freeboard including the manifold height is within Jetty 1 & 2 MLAs working envelopes.

Best regards,

John

----- Original Message -----

Subject:Fw: VESSEL CLEARANCE FOR MT JAVA SEA

Date:2024-11-28 17:01

From:Siti Aisah <siti.aisah@pseraya.com.sg>

To:"Vetting (vetting@safe-ships.sg)" <vetting@safe-ships.sg>

Dear John,

Kindly assist to clear subject vessel for potential fuel oil ops at PSPS.

Thank you.

Regards,

Aisah Mohamed

System Operations

PetroSeraya Pte. Ltd (UEN 200705392E)

450 Alexandra Road #01-01

Singapore 119960

Web ytlpowerseraya.com.sg

From: **Vetting** <vetting@safe-ships.sg>
Date: Thu, Nov 9, 2023 at 12:16 PM
Subject: Re: Vessels Clearance - Java Sea & Nordic Bern
To: Jonathan Goh <jonathan.goh@pseraya.com.sg>
Cc: SystemOps <systemops@pseraya.com.sg>, Othman <othman@pseraya.com.sg>

Dear Jonathan,

Java Sea and Nordic Bern are cleared for fuel oil ops.

Java Sea

Vessel is suitable for Jetty 1 & 2.

There will be tidal restrictions for her berthing/unberthing at Jetty 1 & 2 if her draft exceeds 11.4m and 11.1m respectively.

Her Summer displacement of 127,352MT exceeded Jetty 1 & 2 acceptance criteria of 127,000MT.

Vessel should be reminded that her displacement should not exceed 127,000MT at all times.

Vessel's ballast freeboard including the manifold height is within Jetty 1 & 2 MLAs working envelopes.

Nordic Bern

Vessel is suitable for Jetty 1 & 2.

There will be tidal restrictions for her berthing/unberthing at Jetty 1 & 2 if her draft exceeds 11.4m and 11.1m respectively.

Vessel's ballast freeboard including the manifold height is within Jetty 1 & 2 MLAs working envelopes.

Best regards,
John

----- Original Message -----

SUBJECT:

Vessels Clearance - Java Sea & Nordic Bern

DATE:

2023-11-09 10:50

FROM:

Jonathan Goh <jonathan.goh@pseraya.com.sg>

TO:

"Vetting (vetting@safe-ships.sg)" <vetting@safe-ships.sg>

Dear John,

Please help to vet the subject vessel for fuel oil ops @ Seraya.

Attached is the latest updated Q88 of the vessel. Thanks

Warm Regards,

Jonathan Goh

System Operations Executive

Fuel Management Operations/System Operations

Mobile +(65) 8042 9345

<https://ytlpowerseraya.com.sg/>

PetroSeraya Pte. Ltd. (UEN 200705392E)

450 Alexandra Road #01-01

Singapore 119960